



- KEYNOTE:**
- 03300.H CAST-IN PLACE CONCRETE
  - 03300.C NON-SHRINK GROUT
  - 03300.D CONCRETE SLAB
  - 03300.H EXISTING CONCRETE SLAB
  - 03300.I COMPACTED GRANULAR FILL
  - 04220 UNIT MASONRY
  - 04220.B 8" CONCRETE MASONRY UNIT
  - 04220.C 6" CONCRETE MASONRY UNIT
  - 04220.E 12"x8" CONCRETE MASONRY UNITS
  - 04220.K EXISTING CMU WALL. PATCH ALL HOLES LARGER THAN 1/4" IN SIZE.
  - 04220.M 8"x8"x12" CMU. GROUT CORE SOLID W/ 2-#5 VERTICAL RE-BAR. EXTEND GROUT AND RE-BAR INTO EXISTING CMU FOUNDATION WALL TO FOOTING. (TYPICAL AT CMU BEINGS)
  - 06100 ROUGH CARPENTRY
  - 06100.B TREATED WOOD BLOCKING
  - 06400 CUSTOM CABINET WORK
  - 06400.K WINDOW SILL: PLASTIC LAMINATE ON 3/4" HARDBOARD WITH 1-1/2" BULLNOSE.
  - 07240 EXTERIOR INSULATION AND FINISH SYSTEM
  - 07240.A EIFS: 2" RIGID INSULATION FASTENED TO EXISTING CMU WALL. MECHANICALLY AND WITH ADHESIVE. SEE ELEVATIONS FOR FINISH, COLOR, TEXTURE AND IMPACT DENSITY.
  - 07240.F 3/4" HIGH "V" ACCENT JOINT
  - 07240.G 3/4" WIDE "V" DRIP EDGE
  - 07240.H 2"x4"x4" TREATED WOOD BLOCKING (06100.B) AT EACH AWNING BRACKET. COVER BLOCKING FACE AND EDGES WITH MESH AND FINISH SYSTEM TO MATCH SURROUNDING FINISH. PROVIDE 3/8" JOINT AROUND BLOCKING. SEAL JOINT WITH 07900.A. COORDINATE LOCATION WITH AWNING MANUFACTURER.
  - 07411 MANUFACTURED METAL ROOF PANELS
  - 07411.A RETROFIT METAL ROOFING SYSTEM
  - 07411.C THERMAL SPACER BLOCK
  - 07411.D 6" (R=19 MIN.) BLANKET INSULATION WITH VAPOR BARRIER TO MATCH ROOF PANELS. 6"x6" MIN. INSIDE DIMENSIONS.
  - 07411.H PANEL CLIP
  - 07411.L EAVE CLOSURE
  - 07411.M PANEL STRAP
  - 07411.N GALV. STEEL GUTTER HANGER @ 2'-0" O.C.
  - 07900 JOINT SEALERS
  - 07900.A BACKER ROD AND EXTERIOR SEALANT.
  - 07900.B LATEX SEALANT
  - 07900.C SILICONE SEALANT
  - 07900.D EXTERIOR SEALANT
  - 07900.E 3/8" COMPRESSIBLE JOINT WITH BACKER ROD AND SEALANT. WHERE JOINT (09650) IS USED. ALIGN TILE JOINT OVER CONCRETE JOINT.
  - 08110 STEEL DOORS AND FRAMES
  - 08110.A HOLLOW METAL FRAME WITH MASONRY ANCHOR TIE.
  - 08415 ALUMINUM STOREFRONT
  - 08415.A THERMALLY BROKEN ALUMINUM FRAME
  - 08415.B NON-THERMALLY BROKEN ALUMINUM FRAME
  - 08415.D ALUMINUM SILL SUPPLIED BY STOREFRONT MANUFACTURER. FINISH TO MATCH STOREFRONT FRAME.
  - 08461 AUTOMATIC SLIDING DOORS
  - 08461.A AUTOMATIC SLIDING DOOR UNIT
  - 08520 ALUMINUM WINDOWS
  - 08520.A ALUMINUM WINDOW FRAME (THERMALLY BROKEN)
  - 08520.D ALUMINUM SILL SUPPLIED BY WINDOW MANUFACTURER. FINISH TO MATCH WINDOW FRAME.
  - 08710 DOOR HARDWARE
  - 08710.A THRESHOLD: SET IN BED OF SEALANT. (07900.C)
  - 09260 GYPSUM BOARD SYSTEMS
  - 09260.A 25 GA. 3 5/8" METAL STUDS @ 1'-4" O.C.
  - 09260.C 5/8" TYPE "X" GYPSUM BOARD
  - 09260.F 5/8" TYPE "X" GYPSUM BOARD ON 7/8" HAT CHANNEL. 3-5/8" METAL STUD WITH (1) LAYER OF 5/8" TYPE "X" GYPSUM BOARD ON EACH SIDE. PROVIDE SOUND BATT INSULATION UNLESS NOTED OTHERWISE.
  - 09260.H (1) LAYER 5/8" TYPE "X" FOL BACKED GYPSUM BOARD FASTENED WITH DRYWALL SCREWS 12" O.C. MAX. TO 2-1/2" METAL SCREW STUDS SPACED 2'-0" O.C. STUDS SHALL BE SUSPENDED FROM THE EXISTING BAR JOISTS WITH 16 GA. GALVANIZED TIE WIRES. FIRE TAPE EXCEPT FINISH TAPE WHERE EXPOSED.
  - 09260.K "J" FINISH BEAD
  - 09260.L 2 1/2" METAL STUD
  - 09260.M 5/8" EXTERIOR GYPSUM
  - 09511 ACOUSTICAL CEILINGS
  - 09511.A 2' X 4' SUSPENDED ACOUSTICAL TILE SYSTEM
  - 09650 RESILIENT FLOORING
  - 09650.D 4" VINYL BASE
  - 10536 AWNINGS
  - 10536.A ASTRUP ALUMINUM "FABRI-FRAME": ENGINEERED AND PROVIDED BY AWNING MANUFACTURER.
  - 10536.B ASTRUP "COOLEY BRITE" ERADICABLE BACK-LIT AWNING FABRIC.
  - 10536.C POLYSTYRENE "EGG CRATE" TYPE SOFFIT
  - 10536.D AWNING FRAME BRACKET. PROVIDED BY AWNING MANUFACTURER. ATTACHMENT METHOD MUST BE APPROVED BY THE ARCHITECT.
  - 10652 PANEL OPERABLE PARTITIONS
  - 10652.A OPERABLE PARTITION PANEL
  - 10652.B PARTITION TRACK